


HVDC Network Concept

January 7, 2014
Metairie, Louisiana


MISO Value Proposition



One Time Opportunity to Mine Unused Potential Benefits Spread over the U.S. and Canada

- **The estimated potential value is estimated to be approximately \$50B is obtained from the following categories:**
 - Frequency Response \$5B from 7000MW spinning reserve
 - Load Diversity \$38B from 36,000MW load reduction
 - Wind Diversity \$3B from 4000MW capacity credit
 - Solar Diversity \$1B from 1500MW capacity credit
 - Area Control Error \$3B from 4000MW ACE improvement
 - Carbon Reduction ?
- **Once the potential benefits are mined, the growth to support future transmission lines is small, possibly 0.06%/yr.**

A view of the potential mature HVDC network



Why is MISO sharing information and seeking study participants with this meeting?

- MISO appears to benefit as well as many other Balancing Areas from a proposed HVDC Network.
- No one area or two areas have the diversity to justify significant transmission expansion. Potential study participants need to be identified. Better data is needed and more detailed justifications need to be developed.
- Every Balancing Area's participation is not necessary to justify the HVDC Network, but economy of scale tends towards inclusion of as many Balancing Areas as is feasible. Information may help make a decision to participate in a future study.
- The HVDC Network may be started by building sections that can provide benefits on their own. These projects and participants need to be identified.
- Experience has shown that local stakeholder participation may increase the benefit capture by 20%. For the Sketch, this is about \$4B present value.
- The concepts are new and take time to be understood.

MISO Guiding Principles

- **Guiding Principle 1** – Make the benefits of a competitive energy market available to customers by providing access to the lowest possible electric energy costs
- **Guiding Principle 2** – Provide a transmission infrastructure that safeguards local and regional reliability
- **Guiding Principle 3** – Support existing state and federal renewable objectives by planning for access to all such resources (e.g. wind, biomass, demand side management)
- **Guiding Principle 4** – Creates a mechanism to ensure investment implementation occurs in a timely manner
- **Guiding Principle 5** – Develop a transmission system scenario model and make it available to state and federal energy policy context and inform the choices they face

MISO Conditions to Justify Transmission

- A robust business case that demonstrates value sufficient to support the construction of the transmission project.
- Increased consensus on current and future energy policies.
- A regional tariff that matches who benefits with who pays over time.
- Cost recovery mechanisms that reduce financial risk.

Anticipated Next Steps

- **Work with potential participants –self funded**
 - Obtain better data
 - Mutually understand economic justification processes of Balancing Areas
 - Produce a projected HVDC Network Benefit/Cost calculation
 - Invite stakeholders and regulators to the Question
 - What are the Guiding Principles for each of the three layers of transmission design?
 - What would be the expectations of the HVDC Network
 - The HVDC Network is not expected to be an RTO
- **Form a set of participants by the end of 2014 or earlier that would be willing to participate with staff and or funds for a detailed study to design an HVDC network and set up the governance to manage the study.**

Expectations

- **Energy price differences are not large enough to justify major inter-regional transmission expansion as in the past due to gas setting the price for most Balancing Areas.**
- **Capacity Diversity already exists, has a high value that can justify transmission, is easy to determine, and has a low risk of not occurring-Capacity Diversity will primarily justify the HVDC Network.**
- **The HVDC Network will consist of three layers;**
 - Voltage Source Converters for fast response products as Frequency Response and Regulation-higher cost and higher performance needed
 - Classical HVDC for bulk energy transport for power sales and renewable energy delivery-lower cost
 - AC system changes will be modest-used for Transmission Service to access the HVDC system and deliver scheduled power and energy.

Value Based Planning

- **Provides economic information used to design transmission systems to perform to economic and reliability criteria-principle used to design the Sketch.**
- **Has been proven to be able to design transmission systems on a national basis**
- **Is slightly modified to include capacity products**
- **Value Based Planning has been used by MISO since 2008 and was used to justify the \$5.2B Multi Value Projects in 2011.**
 - MVPs increase the transmission capability to deliver 21,000 MW of wind generation the 25,000 MW MISO Renewable Portfolio Standard.
 - MVPs relieve congestion and increase the market efficiency of MISO
 - MVPs had a benefit to cost ratio of about 1.8:1 across the MISO footprint

Value of Capacity Diversity


- **Capacity Diversity value is produced by sharing existing generation capacity by the use of a transmission system such that the cost of future generation is displaced**
- **The net result is a lower price of wholesale power to the load customer**
- **Increased revenue to existing and future renewable generation may be a benefit**
- **Lower cost of delivered energy through cooperation in the design and use of the HVDC Network**
- **Possible lower carbon production through increased efficiency of existing and future generation**

Sketch Design Assumptions

- **Every Balancing Area in the Partial East, ERCOT and WECC would be able to access the HVDC Network as an economic option**
 - Direct HVDC terminal access
 - AC Transmission Service to the HVDC Costs proportional to potential benefits
 - HVDC Network costs include AC Transmission Service
 - Costs are based on system participation and benefits of the HVDC Network and not by line
- **Assumptions used until more detailed information is available**
 - Wind Capacity Credit increases, fixed price for generation displacement, Transmission Service Costs, one HVDC cost level estimate, etc.

Component Maximum Sizes and Transmission Requirements

Potential Areas for Load Diversity



North East-HQ Potential


- **PJM, NYISO, NEISO, Ontario, Hydro Quebec and the Maritimes (North East) have a potential of about 17,000 MW of Load Diversity exchange**
 - Summer-Winter Peaking –high value
 - HQ may wish only to sell capacity and energy
- **North East- HQ have 850 MW potential for Frequency Response exchange**
- **Wind Diversity is unknown**
- **Indian Point is a logical HVDC terminus that could be a trading hub linked with other HVDC in the area**
- **No economically feasible transmission found in Sketches to link North East to Partial East**

Load Diversity

- **Transmission requirement 50% of Load Diversity**
- **No transmission reserves are allocated as the diversity appears similar to a generator**
- **Value is the Load Diversity * the price of displaced generation:**
 - combustion turbine or
 - the cost change in the generation forecast
- **Example 25,000 MW * \$700,000=\$17.5B of potential benefits**

Potential Load Diversity/Transmission Capacity Potential

2012 Load Data
FERC 714 from Market Ops
From Ventyx




Area Pairs Potential Power Transfer Between Areas for Load Diversity

2012 Load Data

FERC 714 from Market Ops

From Ventyx




Frequency Response Obligation Sharing of Generation Reserves

- The Partial East, WECC and ERCOT have about the same level of Frequency Response Obligation is about 2,700 MW
- The Spinning Reserves used for Frequency Response can be reduced by a factor of three for each area or by 1,800 MW. Each area would carry 900 MW.
- The transmission capacity is 900 MW firm.
- Transmission reserves must be supplied.

Potential Power Transfer Between Areas for Frequency Response Obligation Exchanges

2012 Load Data
FERC 714 from Market Ops
From Ventyx



**2,700 MW Frequency Response
Obligation Reduced to 900 MW
Spinning Reserve-high price**

Transmission Reserves for Frequency Response Obligation Sharing

- **At least three HVDC lines tie the Partial East, WECC and ERCOT**
- **The HVDC Network Sketch is designed to be N-1 self contingent for the Frequency Response Sharing Obligation transmission capacity.**
- **For an 1800 MW total Frequency Response Obligation Sharing delivery, 900 MW would be reserved on each line for Frequency Response allowing for the loss of one line or terminal.**
- **The low outage rate of HVDC and the generation resources from a pool of generation and not individual generators provide a highly reliable resource.**

Frequency Response Dynamic Performance


- Typically the present governor response to large generation disturbances before the frequency starts to recover is 3 seconds.
- With the HVDC Network the response is 2/3 from other asynchronous areas and is delivered near the area with the generation outage with 3 cycles or 60 times faster.
- The net result is that the frequency response in the system with the generation outage is one third the frequency deviation and the frequency drop in the other areas is one third of the frequency drop if the disturbance were in their area.
- In addition the Voltage Source Converter HVDC terminals near the generation outage support voltage that helps the AC system recover faster also.
- The inertia of WECC, ERCOT and the Partial East is available and used to mitigate Frequency events. Only one interconnection inertia is available today and it has a traveling wave time constant and governor response of several seconds before aid is applied.

Transmission and Benefits

- **The total HVDC transmission capacity would be 2,700 MW including transmission reserves.**
- **Benefits for the Sketch were assumed to be:**
 - \$3/MWH premium for Spinning Reserve on an assumed lost opportunity energy price of \$30/MWH
 - As the transmission offers capacity, planning reserves are reduced and the associated cost of generation
 - Energy prices were assumed to be reduced about 0.1% due to a lower operating point on the price-supply curve.


Potential Power Transfer Between Areas for Wind

**25,000 MW
of Wind Generation
Per Interconnection**



Wind Diversity

Normalized 10 Min. Variability for 5 Regional Groups



Wind Variation Reductions


- **The HVDC Network could be used to lower Standby Reserves associated with Wind Variability and may produce value from displaced generation needed for reserves if some other factor is not larger**
- **Actual wind data and forecasts would be preferred for this type of analysis for potential benefit analysis.**
- **Multiple years of actual data should be used for economic justifications. Forecasted data is good for the first pass.**

Capacity Credit versus Increased Capacity


- **Capacity Credit increases with geographic diversity-decreased correlation coefficient**
- **Capacity Credit decreases with increased generation of the same characteristics that are already in the resource mix**
 - Adding more wind or solar in a location that already is included in the resource mix, decreases
 - Capacity Credit
 - Value of **all** wind or solar in the resource mix not just the incremental
- **Selections of HVDC terminal locations and the number of locations can change the total value of the resource mix**

Transmission Increases the Capacity Contribution on Peak for Wind


Due to Diversity Aggregation- 14% MISO now




Wind Correlation vs Distance



Storm Tracks Typically Cross the U.S.



United States - Land-Based and Offshore Annual Average Wind Speed at 100 m



Source: Wind resource estimates developed by AWS Truepower, LLC. Web: <http://www.awstruepower.com>. Map developed by NREL. Spatial resolution of wind resource data: 2.0 km. Projection: Albers Equal Area WGS84.



AWS Truepower™
Where science delivers performance.



NREL
NATIONAL RENEWABLE ENERGY LABORATORY

Wind Capacity Credit Increase


- The NREL Eastern Wind Integration and Transmission Study (EWITS) showed that the capacity credit may increase about 10% over the present MISO 14%.
- Multiple years of wind data are required to evaluate the potential benefit.
- Actual wind data may be added to NREL data.

Transmission and Benefits for Wind Capacity Credit

- If the increase in Wind Capacity Credit is increased by 10% and there is 25,000 MW of wind in each area
- Transmission capacity would be 2,500 MW and no reserves as the exchange would appear to be a generator or load
- Value is the Load Diversity * the price of displaced generation:
 - combustion turbine or
 - the cost change in the generation forecast
- Example $25,000 \text{ MW} * 0.1 * \$700,000 = \$1.8\text{B}$ of potential benefits

Potential Power Transfer Between Areas for Solar

2012 Load Data
FERC 714 from Market Ops
From Ventyx



Solar Capacity Credit

- Solar data is insufficient to determine the capacity credit and variability reductions
- NREL is to have a forecasted data base in 2014
- Actual data will probably only be available on a limited basis
- Benefits cannot be estimated at this time

Transmission Cost \$/MW-Mile by Type

Cross Over Distance


600 kV VSC HVDC

Vs

500 kV AC

216 Miles

Transmission Cost \$/MW-Mile



345

2-345

500

765

650 Mile

600 kV

VSC

HVDC


650 Mile

600 kV

LCC

HVDC

Interactive Generation Resource Screening Chart



Sum of Coincident Loads MW Load Duration Curve

400000

350000

300000

250000

200000

150000

100000

50000


0


MIS



167 333 499 665 831 997 1163 1329 1495 1661 1827 1993 2159 2325 2491 2657 2823 2989 3155 3321 3487 3653 3819 3985 4151 4317 4483 4649 4815 4981 5147 5313 5479 5645 5811 5977 6143 6309 6475 6641 6807 6973 7139 7305 7471 7637 7803 7969 8135 8301 8467 8633

Interactive Generation Resource Screening Chart






Transmission Design Concept

- **Voltage Source Converters may be operated in parallel to Classical Load Commutated Converters using an upgraded transmission line.**
- **Cooperative use of lines may extend the HVDC Network concept economic justification to reach California where there is major load and renewable resources**
- **Solar resources rated at peak load and wind generation rated at 50% load meet about 80% of the energy needs of the aggregated load profile**
 - better data needed for economic justification


Cooperative Use of Transmission Assumptions

- **Voltage Source Converters are about 25% higher in cost than Classic Load Commutated Converters**
- **Transmission capacity can be doubled for a 50% increase in cost by raising voltage 50%.**
- **Doubling current ratings may cost 75% more**
- **Engineering design is needed to refined these assumptions to economic justification levels**
- **Economic distances for transmission can be increased with transmission use cooperation**


Market Area Extension By Cooperative Use of Transmission Load Diversity



Market Area Extension By Cooperative Use of Transmission Frequency Response



United States - Land-Based and Offshore Annual Average Wind Speed at 100 m



Questions

- **Contact:**
- **Dale Osborn**
- **Consulting Advisor**
- **Policy and Economic Studies**
- **MISO**
- **Email: dosborn@misoenergy.org**
- **Phone: 651-632-8471**